

**| Suggested Specifications | Section 10 26 00  
CS Acrovyn® Model P-OMW****Part 1 - General****1.01 Summary**

- A.** This section includes the following types of wall protection systems:
  - 1.** Handrails
- B.** Related sections: The following sections contain requirements related to this section:
  - 1.** Corner Guards, Bumper Guards, Crash Rails, Accent Rails, Wall Covering, Wall Panels, Door Protection; refer to section 10 26 00 "Wall and Door Protection"
  - 2.** Blocking in walls for fasteners; refer to section 09 22 00 "Supports for Plaster and Gypsum Board"

**1.02 References**

- A.** National codes (IBC, UBC, SBCCI, BOCA, OSHA, Life Safety, OSHPD and ADA)
- B.** American Society for Testing and Materials (ASTM)

**1.03 Submittals**

General: Submit the following in accordance with conditions of contract and Division 1 specification section 01 33 00 "Submittal Procedures":

- A.** Product data and detailed specifications for each system component and installation accessory required, including installation methods for each type of substrate.
- B.** Shop drawings showing locations, extent and installation details of handrails. Show methods of attachment to adjoining construction.
- C.** Samples for verification purposes: Submit the following samples, as proposed for this work, for verification of color, finish and end cap attachment and alignment:
  - 1.** 12" (304.8mm) long sample of each model specified including end cap.
- D.** Product test reports from a qualified independent testing laboratory showing compliance of each component with requirements indicated.
- E.** Maintenance data for wall protection system components for inclusion in the operating and maintenance manuals specified in Division 1.

**1.04 Quality Assurance**

- A.** Installer qualifications: Engage an installer who has no less than 3 years experience in installation of systems similar in complexity to those required for this project.
- B.** Manufacturer's qualifications: Not less than 5 years experience in the production of specified products and a record of successful in-service performance.
- C.** Code compliance: Assemblies should conform to all applicable codes including IBC, UBC, SBCCI, BOCA, OSHA, Life Safety, OSHPD and ADA.
- D.** Fire performance characteristics: Provide wood and metal components tested in accordance with ASTM E84 for Class A/1 fire characteristics.
- E.** Impact Strength: Provide wall protection components that have been tested for impact using a ram- type impact test in accordance with the applicable

provisions of ASTM F476 -84.

- F. Single source responsibility: Provide all components of the wall protection system manufactured by the same company to ensure compatibility of color, texture and physical properties.

### 1.05 Delivery, Storage and Handling

- A. Deliver materials to the project site in unopened original factory packaging clearly labeled to show manufacturer.
- B. Store materials in original, undamaged packaging in a cool, dry place out of direct sunlight and exposure to the elements. A minimum room temperature of 40°F (4°C) and a maximum of 100°F (38°C) should be maintained.
- C. Material must be stored flat.

### 1.06 Project Conditions

- A. Materials must be acclimated in an environment of 65°-75°F (18°-24°C) for at least 24 hours prior to beginning the installation.
- B. Installation areas must be enclosed and weatherproofed before installation commences.

### 1.07 Warranty

#### A. Acrovyn 5-year Limited Warranty

- Applies to Interior Wall Protection orders that do not include recommended components or accessories
  - o Assemblies = Brackets, Hardware
  - o Accessories = Primer, Adhesive, Caulk, Trims & Moldings

#### B. Limited Lifetime Systems Warranty

- Applies to CS Interior Wall Protection projects that include all recommended components and accessories related to CS Interior Wall Protection Products.
  - o Assemblies = Brackets, Hardware
  - o Accessories = Primer, Adhesive, Caulk, Trims & Moldings

## Part 2 - Products

### 2.01 Manufacturers

- A. Interior surface protection products specified herein and included on the submittal drawings shall be manufactured by Construction Specialties, Inc., 3 Werner Way, Lebanon, NJ 08833 USA 800-233-8493; email: [cet@c-sgroup.com](mailto:cet@c-sgroup.com)
- B. Drawings and specifications are based on manufacturer's literature from Construction Specialties, Inc. drawings and specifications unless otherwise indicated. Other manufacturers must be approved equal by Architect/Owner.

### 2.02 Materials

- A. Solid Wood Components: Shall be manufactured from plain sawn, FAS grade hardwood, kiln dried to a moisture content of 6% to 10%.
- B. Aluminum: Extruded aluminum should be 6063-T6 alloy. Handrail to be nominal .060" (1.52mm) thickness. Crash rail retainer to be nominal .090" (2.29mm) thickness. Minimum strength and durability properties as specified in ASTM B221.
- A. Stainless Steel: Cast brackets to be type 304 alloy with #4 satin finish. Minimum

strength and durability properties as specified in ASTM A240.

- C. Fasteners: All fasteners to be non-corrosive and compatible with aluminum. All necessary fasteners to be supplied by the manufacturer.

### 2.03 Handrails

- A. Handrails to be CS Acrovyn: Surface mounted handrail and crash rail configuration with mounting brackets spaced as indicated on installation instructions. Attachment hardware shall be appropriate for wall construction.
  - 1. Model P-OMW 6" (152.4mm) high configuration consisting of an oval aluminum handrail, plain faced wood crash rail and matching end caps returning to the wall. Specify P-OMWG for crash rail with optional finished grooves or P-OMWV with optional feature inserts, select from Acrovyn solid colors (limited options). Handrail to be powder coated aluminum; select from standard powder coat finishes. Select from one of Renaissance™ Real Wood species. Dual cantilevered mounting brackets to be stainless steel available with optional powder coat; select from standard powder coat finishes.

### 2.04 Finishes

- A. All wood components shall be factory finished. Wood components to be final coated with water based, high solids, clear lacquer using a two coat process. Finish shall be in accordance with specified AWI finish system. Coverage shall be a minimum of 3-5 mils. Gloss shall be measured on 60° gloss meter as per ASTM D523.
- B. General: Comply with NAAMM "Metal Finishes Manual" for recommendations relative to applications and designations of finishes.

### 2.05 Fabrication

- A. General: Fabricate wall protection systems to comply with requirements indicated for design, dimensions, detail, finish and member sizes.
- B. Preassemble wood components in shop as much as possible to minimize field assembly.
- C. Fabricate components with wood joints lightly chamfered. Provide surfaces free of chipping, dents and other imperfections.

## Part 3 - Execution

### 3.01 Examination

- A. Verification of conditions: Examine areas and conditions under which work is to be performed and identify conditions detrimental to proper or timely completion.
  - 1. Do not proceed until unsatisfactory conditions have been corrected.

### 3.02 Preparation

- A. Surface preparation: Prior to installation, clean substrate to remove dirt, debris and loose particles. Perform additional preparation procedures as required by manufacturer's instructions.
- B. Protection: Take all necessary steps to prevent damage to material during installation as required in manufacturer's installation instructions.

### 3.03 Installation

- A.** Install the work of this section in strict accordance with the manufacturer's recommendations using only approved mounting hardware and locating all components firmly into position, level and plumb.
- B.** Temperature at the time of installation must be between 65°-75°F (18°-24°C) and be maintained for at least 48 hours after the installation.
- C.** Where splices occur in horizontal runs, splice retainer and rail at different locations along the run.

### **3.04 Cleaning**

- A.** General: Immediately upon completion of installation, clean rails and accessories in accordance with manufacturer's recommended cleaning method.
- B.** Remove surplus materials, rubbish and debris resulting from installation as work progresses and upon completion of work.

### **3.05 Protection**

- A.** Protect installed materials to prevent damage by other trades. Use materials that may be easily removed without leaving residue or permanent stains.