

Acrovyn Fungal Resistance Testing



SGS U.S. Testing Company Inc.

291 Fairfield Avenue • Fairfield, NJ 07004-3833 • Tel: 973-575-5252 • Fax: 973-244-1823

Report Number: 116742-01

Date: 12/15/98

Page: 1 of 2

Client: Construction Specialty
 RR #2 State Rt 1043/POB 378
 Milton, PA 17847

Attn.: Jim Fenstermacher

REPORT OF TEST

Subject: Samples submitted and identified by the client as: 10 C/S Group Acrovyn (PVC) Material (2"x2" Squares)

Sample Description: Beige polymeric pieces, textured on one side; smooth on opposite side; 2x2x0.63 inches nominal, received 11/09/98.

Project: Fungal Resistance Testing


Test Dates: 11/13/98 to 12/10/98

Procedure: ASTM G-21

The testing was conducted in accordance with the procedures outlined in ASTM G-21-96, "Determining Resistance of Synthetic Polymeric Materials to Fungi".

Four sample specimens were each placed in petri dishes on sterile mineral salts medium, two face-up (textured) and two face-down, and sprayed with an inoculum the following organisms:

	<u>ATCC #</u>
<i>Aspergillus niger</i>	9642
<i>Penicillium funiculosum</i>	11797
<i>Chaetomium globosum</i>	6205
<i>Gliocladium virens</i>	9645
<i>Aureobasidium pullulans</i>	15233

Prepared by:

 Daniel Drozdowski
 Biological Services

SIGNED FOR THE COMPANY BY:

 D. Keith Goins, Ph.D.
 Manager, Microbiology

Member of the SGS Group

ANALYTICAL SERVICES • PERFORMANCE TESTING • STANDARDS EVALUATION • CERTIFICATION SERVICES
 SGS U.S. TESTING COMPANY INC. REPORTS ARE FOR THE EXCLUSIVE USE OF THE CLIENT TO WHOM THEY ARE ADDRESSED. ANYONE RELYING ON SUCH REPORTS SHOULD UNDERSTAND ALL OF THE DETAILS OF THE ENGAGEMENT. REPORTS REFLECT RESULTS ONLY OF THE STANDARDS OR PROCEDURES IDENTIFIED TO THE TESTS CONDUCTED AND ARE LIMITED TO THE SAMPLES TESTED. TEST RESULTS MAY NOT BE INDICATIVE OF THE QUALITIES OF THE LOT FROM WHICH THE SAMPLE WAS TAKEN. SGS U.S. TESTING COMPANY INC. HAS NOT CONDUCTED ANY QUALITY CONTROL PROGRAM FOR THE CLIENT. NEITHER THE NAME, SEALS, MARKS NOR INSIGNA OF SGS U.S. TESTING COMPANY INC. MAY BE USED IN ANY ADVERTISING OR PROMOTIONAL MATERIALS WITHOUT THE PRIOR WRITTEN APPROVAL OF SGS U.S. TESTING COMPANY INC. THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL WITHOUT THE WRITTEN PERMISSION OF THE SGS U.S. TESTING COMPANY INC. SAMPLES NOT DESTROYED IN TESTING ARE DISPOSED OF AFTER 30 DAYS.