

| Suggested Specifications | Section 10 21 23
Non-Vinyl Shower Curtains

Part 1 – General

1.01 Related Documents

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.02 Summary

- A. This section includes the following:
 - 1. Non-vinyl shower curtains

1.03 Performance Requirements

- A. Curtains: Provide curtain fabrics with the following characteristics:
 - 1. Fabrics are launderable at temperatures of 130 to 160 degrees F (71 Deg C).
 - 2. Fabrics are flame resistant and are identical to those that have passed NFPA 701 when tested by a testing and inspecting agency acceptable to authorities having jurisdiction (AHJ).

1.04 Submittals

- A. Product Data: Submit copies of manufacturer's detailed technical data for materials, fabrication, and physical appearance.
- B. Shop Drawings: Show layout and types of cubicle curtains, sizes of curtains, and number of carriers.
- C. Samples for Verification: Provide samples of the following:
 - 1. Curtain Fabric: 12-inch square swatch or larger sample as required to show complete pattern repeat, from dye lot used for the work, with specified treatments applied

1.05 Warranty

- A. Provide copy of manufacturer's standard warranty.

Part 2 - Products

2.01 Manufacturers

- A. Basis of Design - manufactured by Construction Specialties Subject to compliance with the requirements listed, provide cubicle curtains from the following manufacturer:
Construction Specialties, 3 Werner Way, Lebanon, NJ 08833. Tel: 800.233.8493. Email: cet@c-sgroup.com No substitutions.

2.02 Materials

- A. Shower Curtain:
 - 1. Fabric: Fabric to be non-vinyl, intrinsically fire retardant, and antimicrobial.

2.03 Pattern and Color

<**Note to specifier – please select one of the following standard colors for shower curtains>

- A. Shower Curtain Fabric: Fabric to be CS Shower Shield fabric in the following color:
 - a. Café
 - b. Doeskin
 - c. Snow
 - d. Palm

- e. Blue Moon
- f. Cream
- g. Shadow
- h. Buff

2.04 Fabrication

- A. Shower Curtains to be fabricated as follows:
 - 1. Width: Equal to track (or shower curtain rod) length from which curtain is hung plus 10 percent, but not less than 12" (300 mm).
 - 2. Length: Equal to floor-to-ceiling (or shower rod-to-floor) height minus 2" from finished ceiling at top and 1" above finished floor.
 - 3. Top Hem: Not less than 1" (26 mm) and not more than 1 ½" (40 mm) wide, triple thickness, reinforced with integral web and double stitched.
 - a. Grommets: 2 piece, rolled-edge, rustproof, nickel-plated brass and spaced not more than 6" (150 mm) o.c.
 - 4. Bottom and Side Hems: Not less than 1" (25 mm) wide, reinforced, triple thickness and single stitched.
 - 5. Seams: Not less than ½" (13 mm) wide, double turned and double stitched.
- B. Curtain Tieback: At each termination.

Part 3 – Execution

3.01 Examination

- A. Examine areas and conditions in which the cubicle track system will be installed
 - 1. Complete all finishing operations, including painting, before beginning installation of cubicle tracking system materials.
 - 2. Verify that surfaces and above ceiling supports are ready to receive work.

3.02 Cleaning

- A. At completion of the installation, remove any debris and clean surfaces in accordance with CS cleaning and maintenance instructions.

END OF SECTION