


Test Verification of Conformity

Verification Number: 103877942GRR-001bV

On the basis of the tests undertaken, the samples of the below product have been found to comply with the requirements of the referenced specification/standard at the time the tests were carried out. This verification is part of the full test report and should be read in conjunction with it.

Applicant Name & Address:	Michael Dance Construction Specialties, Inc. 6696 RT 405 HWY PO Box 380 Muncy, PA 17756
Product Description:	Entrance Flooring System
Ratings & Principle Characteristics:	CDPH 01350: This product conforms to formaldehyde and individual VOC requirements specified in California Department of Public Health CDPH/EHLB/Standard Method Version 1.2, 2017 Table 4-1 for the School Classroom, Private Office, and Single-family Residence scenarios as defined in Tables 4-3, 4-5, and B-2 respectively for floor mat applications. LEED v4: Indoor air concentrations for TVOCs are < 0.5 mg/m ³ for floor mat applications for School Classroom, Private Office, and Single-family Residence scenarios.
Models/Type References:	PediTred® G4 with Carpet
Brand Name:	Construction Specialties PediTred® G4
Specification/Standard:	California Department of Public Health CDPH/EHLB/Standard Method Version 1.2, 2017
Verification Issuing Office Name & Address:	Intertek 4700 Broadmoor Ave SE; Suite 200 Kentwood, MI 49512
Test Report Number:	103877942GRR-001b



Signature
Name: Kyle Tanis

Position: Chemist
Date: 01-May-2019

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

ECORE International

76 Acco Dr., York, PA, United States

For the following product(s):

Rubber Tile and Roll Goods:

ECOsurfaces, ECOsurfaces with ECOguard, Basic Fit/ECONights, ECOfit, ECOfit Plus, ECOmax, ECOsmash, QT/ECOsilence, Playguard, dBTile, UltraTile Performance: Beast Plus/Rally/Motivate/Monster/Modzilla

(Maximum thickness: 2.5in)

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-01793

Valid from: October 1, 2021 to September 30, 2022

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI National Accreditation Board

ACCREDITED

ISO/IEC 17065

PRODUCT CERTIFICATION
BODY



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Executive Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA