

Model 6917
6" (152.4 mm) Drainable Split Blade Louver

Material:


Material:	6063-T6 Alloy
Nominal Thickness:	Heads: .060" (1.52 mm) Sills: 0.080" (2.03 mm) Jambs & Mullions: 0.125" (3.18 mm)
Nominal Blade Thickness:	Stationary Blades: 0.081" (2.05 mm) Operating Blades: 0.125" (3.18 mm)
Furnished With:	Birdscreen: ½" (12.7mm) intercrimp aluminum mesh, 0.063" (1.60 mm) diameter wire removeable aluminum bird screen in an aluminum frame
Additional Options (at additional cost):	Insect screen (in lieu of bird screen), Continuous clip angles for attachment Sheet blank off, Insulated blank off Sill pans, Flange frames Integrated glazing frames



Test Summary:
For a 4 Foot by 4 Foot Unit.

Tested with mill finish and no screen


- Free area = 6.49 ft² (0.603 m²)
- Percent free area = 40.5%
- Free area velocity at the point of beginning water penetration (@ 0.01 oz. / ft² of free area based on a 15 minute interval test) = 1250 FPM (6.35 m/s)
- Intake pressure drop at 0.01 oz. / ft² free area velocity = 0.33 in. H₂O (82.0 Pa)



Model 6917
6" (152.4 mm) Drainable Split Blade Louver

Water Penetration Statement

AMCA defines the point of beginning water penetration as the free area velocity at which the AMCA water test has yielded 0.01 or less ounces of water per square foot of louver free area during a 15-minute test period.



Air Velocity in Feet and Meters per Minute Through Free Area

Data corrected to standard air density.
 48" x 48" (121.92cm x 121.92cm) louver tested to figure 5.5.

Free Area Table (Free area in sq. feet and sq. meters)

For additional sizes, please visit:

<https://www.c-sgroup.com/architectural-louvers/louvers-airflow-tool>

Width in Inches and Meters						
	18	24	30	36	42	48
	0.46	0.61	0.76	0.91	1.07	1.22
24	0.65	0.96	1.26	1.56	1.86	2.16
0.61	0.06	0.09	0.12	0.14	0.17	0.20
30	0.98	1.43	1.89	2.34	2.79	3.25
0.76	0.09	0.13	0.18	0.22	0.26	0.30
36	1.31	1.91	2.52	3.12	3.73	4.33
0.91	0.12	0.18	0.23	0.29	0.35	0.40
42	1.64	2.39	3.15	3.90	4.66	5.41
1.07	0.15	0.22	0.29	0.36	0.43	0.50
48	1.96	2.87	3.78	4.68	5.59	6.49
1.22	0.18	0.27	0.35	0.43	0.52	0.60
54	2.29	3.35	4.41	5.46	6.52	7.58
1.37	0.21	0.31	0.41	0.51	0.61	0.70
60	2.62	3.83	5.03	6.24	7.45	8.66
1.52	0.24	0.36	0.47	0.58	0.69	0.80
66	2.95	4.30	5.66	7.02	8.38	9.74
1.68	0.27	0.40	0.53	0.65	0.78	0.91
72	3.27	4.78	6.29	7.80	9.31	10.82
1.83	0.30	0.44	0.58	0.72	0.87	1.01
78	3.60	5.26	6.92	8.58	10.25	11.91
1.98	0.33	0.49	0.64	0.80	0.95	1.11
84	3.93	5.74	7.55	9.36	11.18	12.99
2.13	0.36	0.53	0.70	0.87	1.04	1.21
90	4.25	6.22	8.18	10.14	12.11	14.07
2.29	0.40	0.58	0.76	0.94	1.12	1.31
96	4.58	6.70	8.81	10.92	13.04	15.15
2.44	0.43	0.62	0.82	1.01	1.21	1.41
102	4.91	7.17	9.44	11.71	13.97	16.24
2.59	0.46	0.67	0.88	1.09	1.30	1.51
108	5.24	7.65	10.07	12.49	14.90	17.32
2.74	0.49	0.71	0.94	1.16	1.38	1.61
114	5.56	8.13	10.70	13.27	15.83	18.40
2.90	0.52	0.76	0.99	1.23	1.47	1.71
120	5.89	8.61	11.33	14.05	16.77	19.48
3.05	0.55	0.80	1.05	1.30	1.56	1.81
126	6.22	9.09	11.96	14.83	17.70	20.57
3.20	0.58	0.84	1.11	1.38	1.64	1.91
132	6.54	9.57	12.59	15.61	18.63	21.65
3.35	0.61	0.89	1.17	1.45	1.73	2.01
138	6.87	10.04	13.22	16.39	19.56	22.73
3.51	0.64	0.93	1.23	1.52	1.82	2.11
144	7.20	10.52	13.85	17.17	20.49	23.81
3.66	0.67	0.98	1.29	1.59	1.90	2.21
150	7.53	11.00	14.47	17.95	21.42	24.90
3.81	0.70	1.02	1.34	1.67	1.99	2.31
156	7.85	11.48	15.10	18.73	22.35	25.98
3.96	0.73	1.07	1.40	1.74	2.08	2.41
162	8.18	11.96	15.73	19.51	23.28	27.06
4.11	0.76	1.11	1.46	1.81	2.16	2.51
168	8.51	12.44	16.36	20.29	24.22	28.14
4.27	0.79	1.16	1.52	1.88	2.25	2.61
174	8.84	12.91	16.99	21.07	25.15	29.23
4.42	0.82	1.20	1.58	1.96	2.34	2.72
180	9.16	13.39	17.62	21.85	26.08	30.31
4.57	0.85	1.24	1.64	2.03	2.42	2.82
186	9.49	13.87	18.25	22.63	27.01	31.39
4.72	0.88	1.29	1.70	2.10	2.51	2.92
192	9.82	14.35	18.88	23.41	27.94	32.47
4.88	0.91	1.33	1.75	2.17	2.60	3.02
198	10.14	14.83	19.51	24.19	28.87	33.56
5.03	0.94	1.38	1.81	2.25	2.68	3.12
204	10.47	15.31	20.14	24.97	29.80	34.64
5.18	0.97	1.42	1.87	2.32	2.77	3.22

Height in Inches and Meters

Upper Numerals English Units/Lower Numerals Metric Units