



MODEL DGTR - D & DGTRW - D INSTALLATION INSTRUCTIONS



IMPORTANT INFORMATION

Prior to the commencement of installation, all materials **MUST** be inspected for damage. Any damage must be reported to CONSTRUCTION SPECIALTIES, INC., as soon as possible, so that replacement materials may be furnished without delay.

All work must be completed as per Architect's Approved "Shop Drawings", and in accordance with these Installation Instructions. When installation is complete, all materials must be protected from damage until the Architect's FINAL INSPECTION.

All materials should be arranged in the order that they are to be installed. All hardware required for each portion of the work should be placed with the appropriate materials.

Please review all Approved Shop Drawings and this document to familiarize yourself with all the details and components of this assembly.

IMPORTANT:

READ THROUGH ALL INSTRUCTIONS PRIOR TO STARTING INSTALLATION

4/3/17



Construction Specialties™

6696 Route 405 Highway, Muncy PA 17756
(800) 233-8493 • Fax (570) 546-5169 • www.CSgroup.com

This document is the property of Construction Specialties, Inc. and contains CONFIDENTIAL PROPRIETARY INFORMATION that is not to be disclosed to third parties and is not to be used without approval in writing from Construction Specialties, Inc.

Notes:


Before beginning installation, review the architectural drawings and approved Construction Specialties Inc. shop drawings to familiarize yourself with the joint cover models and locations.

Check all of the joint cover components to confirm that the correct joint cover model and size have been received. Also, check for materials that may have been damaged during shipping. Report all incorrect and/or damaged components to CS at 800-233-8493.

Read through all the steps of these instructions prior to beginning work.

STEP 1

PREPARE BLOCKOUT



BLOCKOUT DIMENSIONS		
DIM. A	DIM. B	DIM. C
2" [50.80mm]	2 1/4" [57.15mm]	6 1/2" [165.10mm]
3" [76.20mm]	3 1/2" [88.90mm]	10" [254.00mm]
4" [101.60mm]	3 1/2" [88.90mm]	11" [279.40mm]

Step 1:


1.1) The blockouts must be prepared to receive the joint cover.

- The blockout width (Dim. B) will vary with model as indicated above or as noted on the CS shop drawings.
- The overall width (Dim. C) will vary with model as indicated above or as noted on the CS shop drawings.
- The blockout depth will typically be approx. 1 3/16" (30.0mm). However, the depth may be adjusted as needed to accommodate a floor finish material when required and as indicated on the architectural drawings and/or CS shop drawings.
- It is recommended that the blockout be formed a minimum of 1/8" deeper to allow the blockouts to be leveled for installation of the joint cover.
- Apply a self leveling grout to the base of the blockouts to provide a continuous, solid, flat and level base for the joint cover. (Note: The blockouts must be level across the width of the joint.)

STEP 2

FRAME INSTALLATION

NOTE:
2" FRAME RECEIVES
SINGLE MASONRY
ANCHOR,
18"[457.20mm] O.C.



Note:

- If a CS Fire Barrier is to be installed in the joint, please review the Fire Barrier Installation Instructions supplied, and if required install the Fire Barrier **BEFORE** installation of CS Seismic Expansion Joint Aluminum Frames.
- If a Vapor Barrier/Waterstop is to be installed in the joint, please review the Vapor Barrier/Waterstop Installation Instructions supplied, and if required install the Vapor Barrier/Waterstop **BEFORE** installation of CS Seismic Expansion Joint Aluminum Frames.
- If there is an expected temperature change of 20°F(+) daily, leave a 1/16" gap between Frames for 10' sections or an 1/8" gap between Frames for a 20' section due the thermal expansion of aluminum. Caulk (by others) in between Frames to seal gap.




Step 2:

- 2.1) Begin installation of the Frames by placing a length of Frame into the blockout. Cut the Frame to length as needed. The Frame is to sit level, flat and parallel to the edge of the joint.
- 2.2) Using the Frame as a template, mark the locations of the Frame anchor bolts.
- 2.3) Remove the Frame and drill the holes for the anchor bolts. The holes are to be drilled with the appropriate size and type of drill bit as indicated by the manufacturer of the CS supplied anchor bolts.
- 2.4) Reposition and anchor the Frame to the slab with the CS supplied anchor bolts following the manufacturer's guidelines.
- 2.5) For Frames located on the opposite side of the joint, locate the backside of the Frame DIM "C"(see chart on page 2) from backside of the Frame on the opposite side of the joint (see detail above). Follow Steps 2.2 through 2.4.
- 2.6) Repeat this installation procedure for any additional lengths of Frame.
- 2.7) For additional lengths of Frame, insert the grooved end of the Alignment Pin, approximately half of its length, into the alignment slots of the Additional Frame.
- 2.8) Align the additional length of Frame with the previously installed Frame and slide together. Make sure the Alignment Pins slide into the slots of the previously installed Frame (see detail above).

Note: Do not install last section of Frames until after Step 3. PAGE 3

STEP 3

TURNBAR INSTALLATION






Step 3:

- 3.1) Begin installation of the Turnbars by determining the number of Turnbars needed for the length of the run.
- 3.2) Determine the location of the Turnbars (see detail above) and mark the location on the Frames with a pencil.
- 3.3) Slide the Turnbars into the Turnbar receivers of the Frames (see detail above) and position the Turnbars to the marked locations.

Notes: The orientation of the Turnbars should all be the same direction or the system will not function. Please note the orientation of the Turnbars in the details above (the side with the part number on it faces up). Model DGTRW-D does not require any Turnbars.

STEP 4

LAST PC. FRAME INSTALLATION



Note:

If there is an expected temperature change of 20°F(+) daily, leave a 1/16" gap between Frames for 10' sections or an 1/8" gap between Frames for a 20' section due the thermal expansion of aluminum. Caulk (by others) in between Frames to seal gap.


Step 4:

- 4.1) Begin installation of last section of Frame by cutting the Frame to length as needed. The Frame is to sit level, flat and parallel to the edge of the joint.
- 4.2) Using the Frame as a template, mark the locations of the Frame anchor bolts.
- 4.3) Remove Frame from blockout and lay Frame beside joint on wood blocking as shown in detail above.
- 4.4) Determine the number of Turnbars needed and mark the location of the Turnbars. Slide the Turnbars into the Turnbar receivers of the Frames (see detail above) and position the Turnbars to proper locations.
- 4.5) Insert the Alignment Pin halfway into alignment slots of the additional length of Frame. Apply small amount of instant adhesive (by others) if necessary to secure.
- 4.6) Pick up the Frames with Turnbars and place into blockout, align the additional length of Frame with the previously installed Frame and slide together. Make sure the Alignment Pin slides into the slot of the previously installed Frame.
- 4.7) Reposition Turnbars to the marked locations.

Notes: The orientation of the Turnbars should all be the same direction or the system will not function. Please note the orientation of the Turnbars in the details above (the side with the part number on it face out). Models DGTRW-D do not require any Turnbars.

STEP 5

CENTER PLATE INSTALLATION



Note:

If there is an expected temperature change of 20°F(+) daily, leave a 1/16" gap between Plates for 10' sections or an 1/8" gap between Plates for a 20' section due the thermal expansion of aluminum. Caulk in between Plates to seal gap.

Step 5:

Note: If you over tighten the Turnbars, they will snap. It is important to follow these instructions.

- 5.1) Begin installation of the Center Plate by first placing a length of the Center Plate beside the joint and cutting required length.
- 5.2) Center the Plate over the joint/Frames. Make sure that the holes of the Center Plate and Turnbars are aligned.

Note: You can do this by shining a light in the holes if necessary and using a wire to line up the holes.



- 5.3) Using the CS supplied wood screws attach the Center Plate to the Turnbars. DO NOT FULLY TIGHTEN.
- 5.4) Once all of the wood screws have been partially fastened, go back through and hand tighten until the head of the screw is flush with the top of the Center Plate plus an additional 1/4 turn.
- 5.5) Repeat these installation instructions for any additional lengths of Center Plate.

Floor to Wall Applications:

- 5.6) Measure 7/8"(22.10mm) above slab surface and mark a line on the wall surface.
- 5.7) Align the top of the vertical flange of the Center Plate with the line.
- 5.8) Using the Center Plate as a template, mark and drill the location for the CS supplied wall fasteners.
- 5.9) Attach the Center Plate using the CS supplied wall fasteners in accordance with the manufacturer's guidelines.
- 5.10) Repeat these installation instructions for any additional lengths of Center Plate.

STEP 6

GASKET INSTALLATION





Step 6:

- 6.1) Complete the installation by inserting the Gaskets. It may be necessary to drive the Gasket in place using a rubber mallet and a wood block. Lubricating the push in areas by spraying them with a light mist of water will also ease the installation. When Gaskets are properly installed, they should be flush with the top surface of the Center Plate and Frames.

STEP 7

COMPLETE INSTALLATION



Step 7:

- 7.1) Installation of the CS Floor Expansion Joint Cover has been completed, remove all residue and foreign matter from the area and joint cover.
- 7.2) Clean the CS Joint Cover and adjoining surfaces with a cleaner that is adequate for surface.
- 7.3) Protect the Joint Cover until the Architect's final inspection.