

Monoflex® Series – Model OFX

PRODUCT DESCRIPTION:

The CS Monoflex® (OFX) fire barrier is blanket type barrier designed for 1"-20" nominal floor and wall expansion joints. Monoflex® has been tested and proven to provide up to 2-hour fire endurance rating, minimize smoke passage and accommodate dynamic movement without degradation of the material. The barriers are listed with Underwriters Laboratories and will meet most current building codes and testing criteria.

BASIC USES

For 1"-20" nominal, horizontal and vertical rated expansion joints for buildings and parking decks. 2-hour rating.



TECHNICAL DATA

PERFORMANCE STANDARDS: UL-2079, ASTM E-1966, ASTM E1399, ASTM E-119
 CODE COMPLIANCE: UBC, SBC, BOCA, IBC

PRECAUTIONS

Refer to Material Safety Data Sheet for detailed health and safety information prior to use.

WARRANTY

CS warrants that its products are manufactured free of defects and conform to the technical data listed. Under this warranty, we will replace (at no charge) any material proven defective when applied in accordance with our written instructions for applications recommended by us as suitable for subject products. CS shall not be liable for any injury, loss or damage, direct or consequential, arising out of the use of the product.

STANDARD UL DESIGN NUMBERS FOR MONOFLEX®	UL DESIGN NUMBER
1-2" Floor 2-Hour Rated	FF-D-0079
3-6" Floor 2-Hour Rated	FF-D-1094
8-12" Floor 2-Hour Rated	FF-D-2017
14-20" Floor 2-Hour Rated	FF-D-3011
1-2" Floor to Wall 2-Hour Rated	FW-D-0056
3-6" Floor to Wall 2-Hour Rated	FW-D-1078
8-12" Floor to Wall 2-Hour Rated	FW-D-2006
14-20" Floor to Wall 2-Hour Rated	FW-D-3006
1-2" Wall 1 & 2-Hour Rated (Gyp. Board)	WW-D-0097
1-2" Wall 2-Hour Rated (CMU)	WW-D-0098
3-6" Wall 1 & 2-Hour Rated (Gyp. Board)	WW-D-1085
3-6" Wall 2-Hour Rated (CMU)	WW-D-1086
8-12" Wall 1 & 2-Hour Rated (Gyp. Board)	WW-D-2018
8-12" Wall 2-Hour Rated (CMU)	WW-D-2019
14-20" Wall 1 & 2-Hour Rated (Gyp. Board)	WW-D-3015
14-20" Wall 2-Hour Rated (CMU)	WW-D-3016