

*If the Manufacturer Notes do not display in the right margin go to [Review and select Show Comments](#)*

**Commented [ES1]:** [www.c-sgroup.com](http://www.c-sgroup.com)

**PART 2 PRODUCTS**

**2.01 Manufacturers**

A. The louvers and related materials herein specified and indicated on the drawings shall be as manufactured by:

Construction Specialties, Inc.  
49 Meeker Avenue  
Cranford, New Jersey 07016  
Telephone: 800-631-7379

Construction Specialties (UK) LTD  
1010 Westcott Venture Park, Westcott,  
Aylesbury,  
Bucks HP18 0XB, United Kingdom.  
Telephone: +44 (0) 1296 652800

Construction Specialties, LLC  
1705 World Trade Centre  
PO Box 9260  
Dubai, U.A.E.  
Telephone: +971-4-3312167

CS Group Construction Specialties Ltd.  
Room 616-617  
No.899 Cross Region Plaza, Lingling Road  
Xuhui District, Shanghai, China 200030  
Telephone: +86-21-64329257

**Commented [ES2]:** Project Gallery  
<http://www.c-sgroup.com/gallery/louvers>

Case Studies  
<http://www.c-sgroup.com/louvers/case-studies>

B. Products equal to the CS materials may be offered providing that the manufacturer and materials are pre-approved at least 10 working days before the bid date.

**2.02 Materials**

- A. Aluminum Extrusions: ASTM B211, Alloy 6063-T5, 6063-T6 or 6061-T6.
- B. Aluminum Sheet: ASTM B3209, Alloy 1100, 3003 or 5005.

**2.03 Fabrication, General**

- A. Provide CS louver models, bird screens, blank-off panels, structural supports and accessories as specified and/or shown on the drawings. Materials, sizes, depths, arrangements and material thickness to be as indicated or as required for optimal performance with respect to strength; durability; and uniform appearance.
- B. Louvers to be mechanically assembled using stainless steel or aluminum fasteners.
- C. Include supports, anchorage, and accessories required for complete assembly.

**Commented [ES3]:** A superior method vs welded assembly.

**2.04 Louver Models**

A. CS 5" (127mm) Deep Storm Resistant Fixed Vertical Louver Model **RSV-5700**

1. **Material:** Heads, sills, jambs and mullions to be one-piece structural aluminum members with integral caulking slot and retaining beads. Mullions shall be sliding interlock type. Blades to be one-piece aluminum extrusions with front lip gutter and multiple secondary gutters designed to catch and direct water to sill. Louvers to be supplied with 4" (101.6mm) high by full depth sill flashings formed from minimum 0.050" (1.27mm) thick aluminum. Sill flashings to have welded side panels. Louvers and sill flashings to be installed in accordance with the manufacturer's recommended procedures to ensure complete water integrity performance of the louver system. Material minimum thickness to be as follows: Heads, sills, jambs and mullions: of 0.075" (1.91mm). Fixed blades: 0.060" (1.52mm).
2. **AMCA Performance:** A 4' x 4' unit shall conform to the following:

<b>Free Area</b>	7.32 sq. ft. (0.68 sq. m.)	
Intake Pressure drop at 900 fpm free area velocity (4.57 m/s)		0.125 in. H2O (31.14 Pa)
Exhaust pressure drop at 900 fpm free area velocity (4.57 m/s)		0.166 in. H2O (41.35 Pa)

3. **Wind Driven Rain Performance:** AMCA certified and licensed to bear the AMCA seal. The louver test was based on a 39.370"(1.00m) x 39.370" (1.00 m) core area. Unit tested at a rainfall rate of 3.0 inches per hour (75 mm/hr) with a wind directed to the face of the louver at a velocity 29.1-mph (13 m/s) and a rainfall rate of 8.0 inches per hour (203 m/s) with a wind directed at the face of the louver at a velocity

**Commented [KR4]:** Storm Resistant louvers are specifically tested and certified in WIND DRIVEN RAIN conditions to simulate real-world weather events. Specify Storm Resistant Louvers anywhere the louver face will be exposed to wind driven rain. Generally, select a louver with a Class A (99%-100% effectiveness rating at rejecting rain under the test conditions). This Class A rating should always apply to the expected actual building service condition for the specific louver location or greater (i.e. "Class A at 1000 fpm free area velocity", where the actual FAV will be 1000 fpm or less based on CFM through the louver).

**Commented [ES5]:** AMCA is the Air Movement and Control Association which is a third party testing agency for the louver industry.  
<http://www.amca.org/>

**Commented [KR6]:** Free area goal is generally around 50%, however many factors impact a louver's selection besides Free Area. Louvers with less than 50% free area may be considered if their pressure drop at project service conditions is agreeable to the Mechanical Engineer. Look for a pressure drop at or below the .15"-.19" at 900 – 1,000 fpm (feet per minute) range for intake louvers. Pressure drop for exhaust louvers can be higher, as deemed acceptable by the ME (mechanical engineer). Note this louver's Free Area is under 50%, but the pressure drop at high velocity FAV is under .15" (desirable)

<http://www.c-sgroup.com/louvers/louwer-selector/free-area-program>

of 50 mph (22.3m/s). The test data shall show the water penetration effectiveness rating at each corresponding ventilation rate.

Core Ventilation Rate (m/s):	0.0	0.5	1.0	1.5	2.0	2.5	3.0	3.5	4.0	4.5	5.0
Core Ventilation Rate (ft/min) 29 & 3:	0	132	197	287	380	472	587	680	780	874	986
Free Area Velocity (ft/min) 29 & 3:	0	261	391	569	754	937	1165	1349	1548	1734	1956
Rating Effectiveness @ 29 & 3	A	A	A	A	A	A	A	A	A	A	A
Effectiveness Ratio @ 29 & 3 (%)										100	99.8
Core Ventilation Rate (ft/min) 50 & 8:	0	96	194	284	400	496	571	676	782	856	977
Free Area Velocity (ft/min) 50 & 8:	0	190	385	563	794	984	1133	1341	1552	1698	1939
Rating Effectiveness @ 50 & 8	A	A	A	A	A	A	A	A	A	A	B
Effectiveness Ratio @ 50 & 8 (%)								99.7	99.5	99.1	98.2
Effectiveness Rating:	A = 1 to 0.99		B = 0.989 to 0.95		C = 0.949 to 0.80		D = 0.799 to 0				

**2.05 Finishes**

- A. General: Fluoropolymer finish complying with AAMA-2605-5 standards. Protect finishes on exposed surfaces prior to shipment. Remove scratches and blemishes from exposed surfaces, which will be visible after completing finishing process.

**Commented [ES7]:** Standard color chart  
<http://www.c-sgroup.com/louvers/colors>

Provide Color as indicated or, if not otherwise indicated, as selected by architect from standard CS Powder Coat colors.

- B. 100% Fluoropolymer Resin Powder Coat System. Finish thickness to be 1.5 to 3.0 mils.
  1. Finish to allow zero VOCs to be emitted into facility of application or at job site.
  2. Finish to adhere to a 4H Hardness rating.
  3. Furnish manufacturer's twenty (20) year warranty for finish.
  4. Finish shall be applied in a wholly owned plant by manufacturer. All supports, blade braces and blades to be painted in the same color.
  5. Polyester powder or solvent based fluoropolymer finishes not acceptable.

**Commented [ES8]:**  
<http://www.c-sgroup.com/louvers/powder-coat>  
<http://www.aamanet.org/general/1/351/aluminum-finishes>

**Commented [ES9]:** CS Powder Coat is available in custom colors. Includes AAMA-2605 20-year warranty, 4H Hardness, no VOC's emitted during application.

OR

- A. General: Comply with NAAMM "Metal Finishes Manual" for finish designations and application recommendations, except as otherwise indicated. Apply finishes in factory. Protect finishes on exposed surfaces prior to shipment. Remove scratches and blemishes from exposed surfaces that will be visible after completing finishing process. Provide color as indicated or, if not otherwise indicated, as selected by architect.
- B. Fluorocarbon Coating
  1. Louvers to be finished with an inhibitive thermo-cured primer, 0.2 mil minimum dry film thickness, and a thermo-cured fluorocarbon coating containing "Kynar 500" resin, 1.0 mil minimum dry film thickness.
  2. All aluminum shall be thoroughly cleaned, etched and given a chromated conversion pre-treatment before application of the Kynar/Hylar coating. The coating shall receive a bake cycle of 17 minutes at 450°F. All finishing procedures shall be one continuous operation in the plant of the manufacturer.
  3. Manufacturer to furnish an extended 20 limited warranty for the Kynar/Hylar coating. This limited warranty shall begin on the date of material shipment.

OR

- B. Three Coat Fluorocarbon Coating
  1. Louvers to be finished with a minimum 1.4 mil (0.035mm) thick full strength 70% resin, 3 coat Fluoropolymer system.
  2. All aluminum shall be thoroughly cleaned, etched and given a chromated conversion pre-treatment before application of the Kynar/Hylar coating. The coating shall consist of a primer, a high metallic

color coat and a clear PVF<sub>2</sub> topcoat. It shall receive a bake cycle of 17 minutes at 450°F. All finishing procedures shall be one continuous operation in the plant of the manufacturer.

3. Manufacturer to furnish an extended 20 limited warranty for the Kynar/Hylar coating. This limited warranty shall begin on the date of material shipment.

OR

**B. Two Coat Fluorocarbon Coating**

1. Louvers to be finished with a minimum 1.0 mil (0.025mm) thick full strength 70% resin, 2 coat Fluoropolymer system.
2. All aluminum shall be thoroughly cleaned, etched and given a chromated conversion pre-treatment before application of the MICA II coating. The coating shall consist of a primer and a pearlescent pigmented PVF<sub>2</sub> topcoat. It shall receive a bake cycle of 17 minutes at 450°F. All finishing procedures shall be one continuous operation in the plant of the manufacturer.
3. Manufacturer to furnish an extended 20 limited warranty for the Kynar/Hylar coating. This limited warranty shall begin on the date of material shipment.

OR

**B. Clear Anodize**

1. Louvers to be given a one hour 215R1 Architectural Class I anodic coating of 0.7 mil (0.018mm) thickness (Aluminum Association designation AA-C22A41).
2. The thickness of the coating shall be tested in accordance with ASTM B244-68.
3. The coating shall be sealed to pass the ASTM B136-77 Modified Dye Stain Test.

OR

**B. Bronze Anodic**

1. Louvers to be given a Bronze Anodic Architectural Class 1 coating of 0.7 mil (0.018mm) minimum thickness; and a minimum weight of 27 mg. per sq. in.
2. The thickness of the coating shall be tested in accordance with ASTM B244-68.
3. The coating shall be sealed to pass the ASTM B136-77 Modified Dye Stain Test.

**2.06 Bird Screens**

- A. Unless otherwise indicated, all louvers to be furnished with mill finish bird or insect screens.
- B. Screens to be 5/8" (15.9mm) mesh, 0.050" (1.27mm) thick expanded and flattened aluminum bird screen secured within 0.055" (1.40mm) thick extruded aluminum frames. Frames to have mitered corners and corner locks.

OR

- B. Screens to be 18 x 16 aluminum mesh 0.011" (0.279mm) diameter wire insect screens secured within 0.055" (1.40mm) thick extruded aluminum frames. Frames to have mitered corners and corner locks.

**2.07 Blank Offs**

- A. Furnish where indicated on the drawings blank-off panels fabricated by the louver manufacturer.
- B. Blank-off panels to be 0.050" (1.27mm) thick aluminum sheet. Panels to be finished with Kynar 500 minimum 1 mil (0.025mm) thick full strength 70% resin Fluoropolymer coating. Color to be selected by the architect.

OR

- B. Blank-off panels to be 1" (25.4mm) thick and to be faced on both sides with 0.032" (0.81 mm) thick aluminum sheet. Panels to be fabricated with an expanded polystyrene (EPS) core having an R-value of 4 (0F\*ft<sup>2</sup>\*h/Btu). Panel perimeter frame to be 0.050" (1.27mm) thick-formed aluminum channels. Panel frame to be mitered at the corners. Panels to be finished to match louvers.

OR

- B. Blank-off panels to be 2" (50.8mm) thick and to be faced on both sides with 0.032" (0.81 mm) thick aluminum sheet. Panels to be fabricated with an expanded polystyrene (EPS) core having an R-value of 8 (0F\*ft<sup>2</sup>\*h/Btu). Panel perimeter frame to be 0.050" (1.27mm) thick-formed aluminum channels. Panel frame to be mitered at the corners. Panels to be finished to match louvers.

End of Section