CS Acrovyn by Design® Wall Panels Demountable Sure Snap™

Unfinished Edge with Trim
Suggested Specifications | Section 10 26 23

Part 1 - General

1.01 Summary

- **A.** This section includes the following types of wall protection systems:
 - 1. Wall Panels
- **B.** Related sections: The following sections contain requirements related to this section:
 - **1.** Handrails, Corner Guards, Bumper Guards, Crash Rails, Accent Rails, Wall Covering, Door Protection; refer to section 10 26 00 "Wall and Door Protection"

1.02 References

- A. National codes (IBC, UBC, SBCCI, BOCA and Life Safety)
- **B.** American Society for Testing and Materials (ASTM)
- **C.** Underwriters Laboratories (UL)

1.03 Submittals

General: Submit the following in accordance with conditions of contract and Division 1 specification section 01 33 00 "Submittal Procedures":

- **A.** Product data and detailed specifications for each system component and installation accessory required, including installation methods for each type of substrate.
- **B.** Shop drawings showing locations, extent and installation details of wall panel products.
- **C.** Samples for verification purposes: Submit the following samples, as proposed for this work, for verification of color, texture, pattern and thickness:
 - 1. Sample of each product specified.
- **D.** Product test reports from a qualified independent testing laboratory showing compliance of each component with requirements indicated.
- **E.** Maintenance data for wall protection system components for inclusion in the operating and maintenance manuals specified in Division 1.

1.04 Quality Assurance

- **A.** Installer qualifications: Engage an installer who has no less than 3 years experience in installation of wall panels similar in complexity to those required for this project.
- **B.** Manufacturer's qualifications: Not less than 5 years experience in the production of specified products and a record of successful performance.
- **c.** Code compliance: Assemblies should conform to all applicable codes including IBC, UBC, SBCCI, BOCA and Life Safety.
- **D.** Impact Strength: Provide assembled wall protection units that have been tested in accordance with the applicable provisions of ASTM F476.
- **E.** Chemical and stain resistance: Provide wall panels with chemical and stain resistance in accordance with ASTM D543.
- **F.** Color match: Provide wall protection components that are computer controlled within manufacturing tolerances and typical limitations of digital printing color matching.
- **G.** Single source responsibility: Provide all components of the wall protection system

manufactured by the same company to ensure compatibility of color, texture and physical properties.

1.05 Delivery, Storage and Handling

- **A.** Deliver materials to the project site in unopened packaging clearly labeled to show manufacturer.
- **B.** Store materials in original, undamaged packaging in a clean, dry place out of direct sunlight and exposure to the elements. A room temperature of 50-100°F (10-38°C) should be maintained.
- **C.** Materials must be stored flat.

1.06 Project Conditions

- **A.** Materials must be acclimated in an environment of 65-75°F (18-24°C) for at least 24 hours prior to beginning the installation.
- **B.** Installation areas must be enclosed and weatherproofed before installation commences.

Part 2 - Products

2.01 Manufacturers

A. Interior surface protection products specified herein and included on the submittal drawings shall be manufactured by Construction Specialties, Inc.

2.02 Materials

- A. Engineered PETG: Material should be high-impact Acrovyn 4000 with Suede texture, nominal .040" (1.02mm) thickness. Chemical and stain resistance should be per ASTM D543 standards as established by the manufacturer.
- B. Particle Board: 3/8" (9.53mm) thick particle board core.
- **C.** Aluminum: Aluminum trims and optional reveals to be alloy 6063 T5 with clear anodized finish; minimum strength and durability properties as specified in ASTM B221.

2.03 Wall Panels

- **A.** Engineered PETG Wall Panels to be CS Acrovyn by Design: Wall panels to be manufactured of .040" (1.02mm) thick Acrovyn by Design sheet in standard Suede texture, factory-bonded to the face side of a 3/8" (9.53mm) thick particle board core. The backside of the panel to be laminated with a moisture resistant barrier.
 - 1. Acrovyn by Design Wall Panel with Unfinished Edge to include aluminum picture frame [1/4" (6.35mm) visible] or aluminum thin trim [1/16" (1.59mm) visible] factory installed on panel. Standard maximum panel size to be 47" x 119" (1.2m x 3.0m). Select from one of Acrovyn by Design standard pattern colorways or supply custom artwork for embedded digital imagery. Overall panel thicknesses of 3/4" (19.05mm) available with demountable Sure Snap™ System mounting hardware mechanically fastened to wall and preinstalled on panel.

2.04 Reveals

- A. Reveal spacing to be as narrow or wide as the following allow:
 - 1. Painted wall.
 - 2. Acrovyn reveals to consist of 1 1/2" (38.1mm) wide strips of .040" (1.02mm) thick sheet.
 - 3. Aluminum reveals to be 1 1/2" (38.1mm) wide x .024" (0.61mm) thick.

2.05 Fabrication

A. General: Fabricate wall panels to comply with requirements indicated for design, dimensions, detail, finish and sizes.

2.06 Finishes

A. General: Comply with NAAMM "Metal Finishes Manual" for recommendations relative to applications and designations of finishes.

2.07 Accessories

A. Acrovyn Wall Panels shall be furnished as a complete packaged system, including appropriate demountable hardware.

Part 3 - Execution

3.01 Examination

- **A.** Verification of conditions: Examine areas and conditions under which work is to be performed and identify conditions detrimental to proper or timely completion.
 - 1. Do not proceed until unsatisfactory conditions have been corrected.

3.02 Preparation

- **A.** Surface preparation: Prior to installation, clean substrate to remove dirt, debris and loose particles. Perform additional preparation procedures as required by manufacturer's instructions.
- **B.** Protection: Take all necessary steps to prevent damage to material during installation as required in manufacturer's installation instructions.

3.03 Installation

- **A.** Install the work of this section in strict accordance with the manufacturer's recommendations using approved demountable hardware.
- **B.** Temperature at the time of installation must be between 65-75°F (18-24°C) and be maintained for at least 48 hours after the installation to allow for proper adhesive set up.
- C. Relative humidity shall not exceed 80%.
- **D.** Do not expose wall panels to direct sunlight during or after installation. This will cause the surface temperature to rise, which in turn will cause bubbles and delamination.

3.04 Cleaning

- **A.** General: Immediately upon completion of installation, clean wall panels and accessories in accordance with manufacturer's recommended cleaning method.
- **B.** Remove surplus materials, rubbish and debris resulting from installation as work progresses and upon completion of work.

3.05 Protection

A. Protect installed materials to prevent damage by other trades. Use materials that may be easily removed without leaving residue or permanent stains.