


STORM RESISTANT LOUVERS – MODEL RS-4700



**DO NOT
CAULK SILL
OF LOUVER**

SECTION VIEW

.050" FORMED ALUM. SILL PAN
SET IN A BED OF SEALANT
(FINISH TO MATCH LOUVER)

PLAN VIEW

SCREENS

- SCREEN NOT REQUIRED
- SCREEN REQUIRED
- INTERIOR MOUNTED
- EXTERIOR MOUNTED
- BIRDSCREEN-5/8" EXP. ALUM.
MESH IN ALUMINUM FRAME.
(MILL FINISH)
- INSECT SCREEN (18x16 MESH)

FINISHES

- STANDARD MILL
- FLUOROPOLYMER POWDER COAT
 - (1) OF CS STD. COLORS
 - CUSTOM COLOR, CS REQUIRES
A COLOR CHIP FOR MATCHING
- ARCHITECTURAL CLASS I (DK. OR MED.)
BRONZE ANODIC COATING
- 204-R1 CLEAR ANODIZE
- OTHER _____

CS EXTRUDED ALUM STORM RESISTANT LOUVER
MODEL RS-4700. FRAMES TO BE FABRICATED
FROM 6063-T6 ALLOY, WITH REINFORCING BOSSES
AND A NOMINAL .063" MATERIAL THICKNESS.
ALL FASTENERS TO BE STAINLESS STEEL.

WIND LOAD = PSF

| MARK | QTY. | "A" DIM. | "B" DIM. | NUMBER OF MULLIONS | LOCATION | REMARKS |
|------|------|----------|----------|-----------------------|----------|---------|
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |

Construction Specialties, Inc.
3 Werner Way
Lebanon, New Jersey 08833
800-233-8493

| | | |
|-----------|--------------|----------|
| PROJECT: | DRAWN BY: | CKD. BY: |
| CUSTOMER: | DATE: | |
| ARCH'T: | DWG. NO: | |
| AGENT: | SHEET 1 OF 1 | |